

## CHAPTER 27 HAZARDOUS MATERIALS - GENERAL PROVISIONS

SECTION 2703.1.1  
IFC Interpretation No. 21-05  
2003 Edition  
Issued: 08-19-05

**2703.1.1 Maximum allowable quantity per control area.** The maximum allowable quantity per control area shall be as specified in Tables 2703.1.1(1) through 2703.1.1(4).

For retail and wholesale storage and display in Group M occupancies and Group S storage, see Section 2703.11.



**Q:** Do the quantities of liquefied petroleum gas provided in Chapter 38 take precedence over the maximum allowable quantities per control area in Table 2703.1.1(1) for LP-gas with respect to determining occupancy classification?

**A:** No. Occupancy classifications are determined by the provisions in the *International Building Code*, which provides no exceptions to the applicability of [F]Table 307.7(1) Maximum Allowable Quantities per Control Area in determining occupancy classifications.

---