

**CHAPTER 23  
HIGH PILED COMBUSTIBLE STORAGE**

**SECTION 2306.6.1.1  
IFC Interpretation No. 36-04  
2003 Edition  
Issued: 11-04-05**

**2306.6.1.1 Number of doors required.** A minimum of one access door shall be provided in each 100 lineal feet (30 480 mm), or fraction thereof, of the exterior walls which face required fire apparatus access roads.



**Q:** Where fire department access doors are required by Table 2306.2, Section 2306.6.1.1 requires the doors to be provided in each 100 lineal feet of exterior wall, or fraction thereof. Are the access doors required to be located such that the maximum distance between each door does not exceed 100 lineal feet?

**A:** Yes. The required openings must be distributed such that the lineal distance between adjacent openings does not exceed 100 feet.

