

**CHAPTER 24  
GLASS AND GLAZING**

**SECTION 2405.5  
IBC Interpretation No. 10-04  
2003 Edition  
Issued: 02-01-06**

**2405.5 Unit skylights.** Unit skylights shall be tested and labeled as complying with *101/I.S.2/NAFS Voluntary Performance Specification for Windows, Skylights and Glass*. The label shall state the name of the manufacturer, the approved labeling agency, the product designation and the performance grade rating as specified in 101/I.S.2/NAFS. If the product manufacturer has chosen to have the performance grade of the skylight rated separately for positive and negative design pressure, then the label shall state both performance grade ratings as specified in 101/I.S.2/NAFS and the skylight shall comply with Section 2405.5.2. If the skylight is not rated separately for positive and negative pressure, then the performance grade rating shown on the label shall be the performance grade rating determined in accordance with 101/I.S.2/NAFS for both positive and negative design pressure, and the skylight shall conform to Section 2405.5.1.



**Q:** Are unit skylights as described in Section 2405.5 of the *2003 International Building Code* required to comply with all the requirements of the referenced standard *101/I.S.2/NAFS Voluntary Performance Specification for Windows, Skylights and Glass Doors* that are applicable to unit skylights?

**A:** Yes. Where compliance to any specifically identified portion(s) of any standard referenced in the International Codes is not provided in the text of the code, compliance with all applicable provisions in the referenced standard is required.

---