

**CHAPTER 4  
GAS PIPING INSTALLATIONS**

**SECTION 410.3  
IFGC Interpretation No. 70-07  
2006 Edition  
Issued: 04-29-2008  
FG\_06\_70\_07**

**410.3 Venting of regulators.** Pressure regulators that require a vent shall be vented directly to the outdoors. The vent shall be designed to prevent the entry of insects, water and foreign objects.

**Exception:** A vent to the outdoors is not required for regulators equipped with and labeled for utilization with an approved vent-limiting device installed in accordance with the manufacturer's instructions.



**Q:** In accordance with the provisions of Section 410.3 of the *International Fuel Gas Code*, is a gas line pressure regulator (2psi) with a vent limiter permitted to be located in a mechanical room that contains electric heating and/or air-handling equipment when the mechanical room serves as a plenum?

**A:** Yes. A gas line pressure regulator (2psi) with a vent limiter, installed in accordance with the manufacturer's installation instructions, is permitted to be located in mechanical equipment room plenums.

---